



SIRIM QAS INTERNATIONAL SDN. BHD.

(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri, Seksyen 2, Peti Surat 7035, 40700 Shah Alam, Selangor Darul Ehsan, Malaysia
Tel : 603-5544 6400 Emel : cserviceqas@sirim.my www.sirim-qas.com.my

File No : P5-018995
Licence No : FL000155

Date : 17/11/2023

BRD NEW MATERIALS (MALAYSIA) SDN. BHD.
LOT 577, JALAN MERBAU, BATU 7 1/2
JALAN KAPAR KAMPUNG PEREPAT
42200 KAPAR
SELANGOR, MALAYSIA

Attn : SUSANA JIANG

Tel No : 86-13588073756

Fax No : -

Dear Sir/Madam,

Fire Listing Licence

Product : INSULATION PANEL (ROCKWOOL CORE)
Standard : BS 476 : PART 6 : 1989 + A1 : 2009 BS 476 : PART 7 : 1997

With regards to your request for new/renewal/changes of licence(s) under the SIRIM Fire Listing Licence scheme, enclosed please find the copy of the licence(s) and the certification report(s) for your safe keeping.

For enquiry, please contact

Officer Name : NURUL IZZAH BINTI NORZARI
Contact No : 03-55446456
Email : izzahn@sirim.my

Thank you.

This is a computer generated document. No signature is required.

SIJIL BARANGAN TERSENARAI

Product Listing Certificate



**SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
SIRIM QAS International Sdn. Bhd. hereby grants to**

**BRD NEW MATERIALS (MALAYSIA) SDN. BHD.
LOT 577, JALAN MERBAU, BATU 7 1/2
JALAN KAPAR KAMPUNG PEREPAT
42200 KAPAR
SELANGOR, MALAYSIA**

**Sijil untuk menggunakan Tanda Barangan Tersenarai
a certificate to use the Listed Product Mark on**

INSULATION PANEL (ROCKWOOL CORE)

Please refer to detail in the SCHEDULE

**sebagai mematuhi keperluan
as complying with**

**BS 476 : PART 6 : 1989 + A1 : 2009
BS 476 : PART 7 : 1997**



Nur Fadhilah binti Muhammad
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SCHEDULE

BRD NEW MATERIALS (MALAYSIA) SDN. BHD.



Trade Mark : BRDECO
Model : ROCKWOOL SANDWICH PANEL
Rating : Fire Propagation Index, I: 3.2, 2.2, 1.8 & 1.7;
Surface Spread of Flame: CLASS ONE
Type : FLAT PANEL
Size : Panel Thickness: 50mm - 150mm
Core Density: 100kg/m³ & 120kg/m³
Panel Skin Thickness, TCT: 0.6mm (External) & 0.5mm (Internal)

TEST REPORT NO. : 2023FE0564, 2023FE0565, 2023FE0566, 2023FE0567,
2023FE0568, 2023FE0569, 2023FE0570, 2023FE0571

Factory Name and Location :
BRD NEW MATERIALS CO., LTD.
WEST SIDE, SOUTH OF WEIWU ROAD
CHANG'GE CITY
461500 XUCHANG
HENAN, CHINA

End of page